

FDB033262 - COMPLIANCE - PRODUCT SPECIFICATIONS

BIDDER NAME:
MAKE & MODEL OF 10 YR BATTERY LIFE SMOKE / FIRE ALARMS
WARRANTY INFORMATION
MAKE & MODEL OF 10 YR BATTERY LIFE SMOKE / FIRE/ CO ALARMS
WARRANTY INFORMATION

BIDDER COMPLIANCE

Recognizing that placement of smoke/fire alarms and smoke/fire/CO alarms might make it difficult for the intended recipients to reach the smoke/fire alarms and smoke/fire/CO alarms must meet the following specifications:

	COMPLIANCE	
	YES	NO
1. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must have both ionization sensors and photoelectric sensors.		
2. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must have a 10 year, sealed in, lithium battery.		
3. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must have a tamper resistant design.		
4. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must have a test button.		
5. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must have a silence feature.		
6. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must have an indicator Yes which shows that the unit is operating normally.		
7. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must have an "end-of Yes life" warning.		
8. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must have a 10 year warranty.		
9. Smoke/Fire alarm & Combination Smoke/Fire/CO alarm must be UL Listed.		

	BIDDER COMPLIANCE	
	YES	NO
Examples of acceptable smoke and combination alarms include:		
1. Universal Smoke Sensing Technology 2-in-1 #MI3050SB		
2. Universal Security Instruments 3-in-1 Smoke, Fire and Carbon Monoxide #MIC3510SB		